


# TS-550 evo Quick Reference Guide

## Fuel Management System

### Home Screen



### Navigation Dash Board



**Home:** Directs users to the Home screen.



**Back:** Navigates to the previous screen



**Print:** Prints currently displayed data



**Help:** Displays help information

### One-Touch Buttons



The One-Touch Buttons are programmable shortcuts to perform specific console functions

**Note:** Setup of the One Touch Buttons must be performed by a trained and certified technician.

### Text Entry

When needed, a text entry screen is displayed.



### Quick Jump Menu

From any screen, access the Quick Jump Menu (QJM) by clicking the down arrow.



Brings up:



The QJM allows you to access different sections of the TS-550 evo quickly.

### System Status Bar



The system status bar will be Green and display All Systems Normal when the system has no alarms.




The system status bar will turn Red and will scroll through all active alarm, when the system has any alarms.

### Alarms

Pressing the System Status Bar at any time will direct the user to the Active Alarm screen where alarm and application events histories can be viewed.

Alarm History & Application Event History can be viewed by selecting the appropriate tab:



### Clear Active Alarms

A certified technician can help diagnose alarm issues that might come up, record your Service Company's contact information on the next page.

### To Display:

- Gross Volume
- Gross Level
- Product Temperature
- Net Volume
- Water Volume
- Water Level

Press  to open the QJM.


Press  to access the Tank Summary Screen

Press  to display more tanks, if applicable.

Select the tank icon for details about that tank.



This will display the Tank Inventory Detail Screen:



Pressing the print button while on the Tank Inventory Screen will print an Inventory Report for all tanks.

### To Enter a Password

The TS-550evo will prompt the user to enter a password when required to perform the selected function. Use the keyboard displayed to enter the correct password.

### To Generate Reports

Press  to open the QJM.

Press  to access the Report Menu

Select the type of report and the time period the report will represent.



Select the delivery method.

-  Print (requires an internal or external printer)
-  Email (requires SMTP server configuration)
-  Fax (requires an internal modem & phone line)

### To Force a Tank Leak Test

Press  to access the Tank Summary Screen.

Press  to select the desired tank to test.

Press  to access the tank control menu.

Select the desired test: Monthly or Annual:




### To Force a Line Leak Test

Press  to access the Line Summary Screen.

Press  to select the desired line to test.

Press  to access the line control menu.

Select the desired test: Gross, Monthly or Annual:



Enter the service company's information below.

Name	Number
	( ) -
	( ) -

Note: Alarms cannot be cleared manually. Alarms will clear automatically when the condition that created the alarm has been corrected.

 **Franklin Fueling Systems**  
www.franklinfueling.com

3760 Marsh Road • Madison, WI 53718, U.S.A.  
Tel: +1 608 838 8786 • Fax: +1 608 838 6433  
Tel: USA & Canada 1 800 225 9787 • Tel: México 001 800 738 7610

**Franklin Fueling Systems GmbH**  
Rudolf-Diesel-Strasse 20 • 54516 Wittlich, GERMANY  
Tel: +49-6571-105-380 • Fax: +49-6571-105-510